

Fire Test Certificate – Specimen

Fabric: Voile 3.0
Type: EN13501-1

Trevira-Markenantrag

Seite 1 von 2

Application for approval of the trademark TREVIRA®

Trevira
THE FIBRE COMPANY

Trevira GmbH
Markenprüfung /
Trademark Testing
Technikum, Gebäude 515
Max-Fischer-Straße 11
D-86389 Bobingen

| | | | |
|----------------------|-----------------------------|---------------|---------------|
| Name / Signature | 01.04.2014 | | |
| Trademark | Trevira CS | | |
| Article | TCS Voile FR, Art. Nr. 3779 | | |
| End Use | Drapes | | |
| Other uses | gewaschen | | |
| Composition | 100% Trevira CS | | |
| Fabric weight (g/sm) | ca. 43 | | |
| <u>Yarn Details</u> | <u>Warp</u> | | |
| Yarn titre/ count | -- | | |
| Trevira Type | -- | | |
| Yarn supplier | -- | | |
| | <u>Weft 1</u> | <u>Weft 2</u> | <u>Weft 3</u> |
| Yarn titre/ count | -- | -- | -- |
| Trevira Type | -- | -- | -- |
| Yarn supplier | -- | -- | -- |

Approval: 05.08.2013

(This Trademark approval is valid for a period of 5 years from the date of issue).


The tested article TCS VOILE FR, ART.NR. 3779 with application no. 131130 is granted approval for the trademark Trevira CS.

This article has been tested according to DIN 4102 part 1 and qualifies for class B1.

This article can meet the requirements for class M1 according to the French standard NF P 92-503-507.

Trevira CS fabrics in a weight range of 42 g/m² to 420 g/m² meet the requirements according to the Russian standard GOST R 50810-95 and are classified as hardly flammable textil fabrics. Test Report #9-2PB-08/11 dd. 08.08.2011 from "EXPERT" Fire Safety Test Laboratory Moscow.

This article qualifies for class B-s1, d0 according to the European Standard EN 13501-1. Trevira CS has been approved by the DIBt with the General Building Inspectorate Approval, Approval No. Z-56.25-3573 dd. 2 May 2013.



Trevira GmbH, Trademark Service