

Fire Test Certificate – Specimen

Fabric: Trevira CS Silk
Type: B1

Application for approval of the trademark TREVIRA®

Trevira THE FIBRE COMPANY

Trevira GmbH
Markenprüfung /
Trademark Testing
Technikum, Gebäude 515
Max-Fischer-Straße 11
D-86399 Bobingen

Trademark Trevira CS
Article 19 9913, 199923 & 19 9922

Composition 104 091 weft

Fabric weight (g/sm) 68 / 108

Yarn Details

Warp

Yarn titre/ count 50 140

Trevira Type 691

Yarn supplier Trevira

	Weft 1	Weft 2	Weft 3
Yarn titre/ count	167 164	--	--
Trevira Type	691	--	--
Yarn supplier	Trevira		

Approval: 28.12.2012

(This Trademark approval is valid for a period of 5 years from the date of issue).

The tested article 199913, 199923, 199922 with application no. 122610 is granted approval for the trademark Trevira CS.

This article has been tested according to DIN 4102 part 1 and qualifies for class B1.

This article has been tested according to NF P 92-504 (Propagation of flames) and thus passes the requirements according to NF P 92-503-507, class M1.

35.01.2013 

Trevira GmbH, Trademark Service